



August 16, 2013

Scott Bergsbaken
Specialty Products Group
6254 Skyway Road
P.O. Box 915
Smithville, ON LOR 2AO

Re: Vapor Lock ASTM C494 Compliance

Tourney Consulting Group (TCG) is able to confirm that Vapor Lock, as supplied by Specialty Products Group and based on the concrete properties results to date (6 months), meets the physical requirements of ASTM C494 Type S and qualifies for provisional compliance.

TCG laboratories are AASHTO accredited, CCRL inspected, and USACE validated. In addition, TCG participates in the AMRL and CCRL Proficiency Sample Testing Programs. All sample preparation and testing was performed in accordance with the applicable sections of ASTM C494 and the documents referenced therein.

ASTM C494 essentially assesses the "harmlessness" of a Type S admixture. As required by the standard, three (3) concrete batches containing the Vapor Lock at a dosage rate of 10 oz/cwt were fabricated, sampled, and tested. TCG evaluated setting time (both initial and final) via ASTM C403; compressive strength (ASTM C39) at multiple ages; flexural strengths (ASTM C78) at multiple ages; freeze/thaw durability (ASTM C666), and length change/shrinkage (ASTM C157-Modified). In all cases, the results met or exceed the requirements for compliance.

We appreciate the opportunity to provide our services to you on this project. Should you have any questions or comments regarding this summary, please feel free to contact me.

Sincerely,
TOURNEY CONSULTING GROUP, LLC

A handwritten signature in blue ink, appearing to read "Glenn E. Schaefer".

Glenn E. Schaefer
VP of Operations